

ATTESTATION OF CONFORMITY

Issued to: GACIA ELECTRICAL APPLIANCE CO., LTD.
No.1 Nanxijiang Road, Daqiao Industrial Zone, Beibaixiang Town, Yueqing
325603 Zhejiang, China

For the product: Residual current operated circuit-breakers with integral overcurrent protection (RCBO)

Trade name: GACIA

Type/Model: PL8HM, PL8HE, PL8NM, PL8NE, L80M, L80E, L80M-R

Ratings: 1P+N, Ue: 230 Vac, 50 Hz, In: 6, 10, 16, 20, 25, 32 A, B and C type
IΔn: 30, 100, 300 mA, type A and AC, without time-delay
Ics = Icn = 6 kA, IΔm = 3 kA, energy limiting class 3
Safety distance "a" (grid): 45 mm

Manufactured by: GACIA ELECTRICAL APPLIANCE CO., LTD.
No.1 Nanxijiang Road, Daqiao Industrial Zone, Beibaixiang Town, Yueqing
325603 Zhejiang, China

Subject: Type Test

Requirements: EN 61009-1:2012, EN 61009-1:2012/A1:2014, EN 61009-1:2012/A2:2014,
EN 61009-1:2012/A11:2015, EN 61009-1:2012/A12:2016, EN 61009-2-1:1994,
EN 61009-2-1:1994/A11:1998, IEC 61009-1:2010, A1:2012, A2:2013,
IEC 61009-2-1:1991

Remark: This Attestation replaces AoC no. 3310107.01A issued on 2016-06-02.

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in reports no 3317032.50 issued on 2020-06-15 and 3307822.50 issued on 2015-09-29.

This Attestation implies that the examined types are in accordance with the standards designated under the Low voltage directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

Wenzhou, Zhejiang, 06 July 2020

Number: 3317032.01A

DEKRA Testing Services (Zhejiang) Co., L td.

Ms J Guo
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

