

ATTESTATION OF CONFORMITY

Issued to: GACIA ELECTRICAL APPLIANCE CO., LTD.
No.1 Nanxijiang Road, Daqiao Industrial Zone, Beibaixiang Town, Yueqing,
325603 Zhejiang, China

For the product: Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBO)

Trade name: GACIA

Type/Model: PL8M4

Ratings: 3P+N, $U_e = 400 / 415 \text{ Vac}$, 50 / 60 Hz
 $I_n = 6, 10, 16, 20, 25, 32, 40 \text{ A}$; B and C type
 $I_{\Delta n} = 30, 100, 300 \text{ mA}$, type A and AC, without time-delay
 $I_{cs} = I_{cn} = 6 \text{ kA}$, $I_{\Delta m} = 3000 \text{ A}$
Energy limiting class 3

Manufactured by: Zhejiang Meywon Electric Co., Ltd.
Cao Tian Hou Village, Liushi Town, Yueqing 325604 Zhejiang, China

Subject: Type Test

Requirements: EN 61009-1:2012, EN 61009-1:2012/A1:2014, EN 61009-1:2012/A2:2014,
EN 61009-1:2012/A11:2015, EN 61009-1:2012/A12:2016, EN 61009-2-1:1994,
EN 61009-2-1:1994/A11:1998, IEC 61009-1:2010, IEC 61009-1:2010/A1:2012,
IEC 61009-1:2010/A2:2013, IEC 61009-2-1:1991

Remark: This attestation is based on 3315502.01A issued on 2019-07-11.

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no 3318752.50 issued on 2020-09-02.

This Attestation implies that the examined types are in accordance with the standards designated under the Low voltage directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

Wenzhou, Zhejiang, 21 September 2020 Number: 3318752.01A

DEKRA Testing Services (Zhejiang) Co., Ltd.

Ms J Guo
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

